

CERTIFICATE OF COMPLIANCE

Certificate Number 20180406-S35836
Report Reference S35836-20161220
Issue Date 2018-APRIL-06

Issued to: MAPLE ARMOR FIRE ALARM DEVICE CO LTD
8866 Blvd Du Quartier
Brossard
QC J4Y 0R2 CANADA

**This is to certify that
representative samples of**

HEAT-AUTOMATIC FIRE DETECTORS
Fire Alarm Subassembly –
Heat Detector head, intelligent (addressable), Model
FW521 combination 135°F fixed temperature and 15°F/min
rate of rise.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 521, Heat Detectors for Fire Protective Signaling
Systems
CAN/ULC S530, Heat Actuated Fire Detectors For Fire
Alarm Systems

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

