

CERTIFICATE OF COMPLIANCE

Certificate Number 20181220-S35854
Report Reference S35854-20151023
Issue Date 2018-DECEMBER-20

Issued to: MAPLE ARMOR FIRE ALARM DEVICE CO LTD
8866 Blvd Du Quartier, Brossard
QC J4Y 0R2 CANADA

**This certificate confirms that
representative samples of**

BOXES, NONCODED
Boxes, Non-Coded, Conventional Manual Stations, Models FW751,
FW751C, FW752, FW752C.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 38, Manual Signaling Boxes for Fire Alarm Systems
CAN/ULC-S528-14, Manual Stations for Fire Alarm Systems,
Including Accessories

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

